



Strebord 35mm FD30

Strebord 44mm FD30

Strebord 54mm FD60

**STREBORD
PARTICLEBOARD DOOR CORES**

Strebord particleboard is the market leader for both 35mm & 44mm FD30 and 54mm FD60 fire-rated, as well as non-fire-rated door cores. They are very robust and manufactured to close tolerances to suit modern joinery processes. They can be cut to size and delivered to site for quick, easy installation.



- Our most versatile door core - fully-tested in variety of arrangements for fire & acoustic performance.
- Certifiable under the main UK third-party certification bodies.
- Security evidence available to PAS24: 2016.
- FSC chain of custody certified as standard*
- Mechanically durable – the only product certified under the Q Mark “Enhanced Lifetime Performance of Doors” scheme.
- Fully tested and certifiable options for panel/groove recessing.
- Options available for perimeter framing (traditional construction).

PERFORMANCE SUMMARY

Core Variant	Composition			Thickness (mm)				Fire				App.		Max db(Rw)	PAS24 Security	Thermal Range	Certification			COC			Perimeter Framing	Recessed Panels	
	Particleboard	Solid Timber	Specialist	35	44	54	57	FD30	FD60	FD90	FD120	Internal	External				Certifire	Q Mark	IFCC	FSC	PEFC	EUTR			DD171/BS EN 1192
35	✓			✓				✓				✓					✓		✓	*	✓		E1		
44	✓				✓			✓				✓		35	✓		✓	✓	✓	*	✓	✓	E1		✓
54	✓					✓		✓	✓			✓		36	✓		✓	✓	✓	*	✓	✓	E1		✓



*PEFC available if specified at point of order

STREBORD 35

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2349mm	915mm	1017mm	2135mm	1 No 15x4	1 No 15x4	-	A12137
ULSASD	2299mm	915mm	992mm	2135mm	1 No 15x4	1 No 15x4	-	A12137
LSADD	2249mm	915mm	967mm	2135mm	1 No 15x4	1 No 15x4	1 No 15x4	A12137
ULSADD	2199mm	915mm	942mm	2135mm	1 No 15x4	1 No 15x4	1 No 15x4	A12137

30 Minutes Fire Performance – IFC

-

30 Minutes Fire Performance – Certifire

-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

Fire door evidence.
Access all areas with
wizardoorer.co.uk

Evaluate. Compare. Specify.

Developed by Falcon Panel Products, **Wizardoorer** is a new online resource to provide fire door specialists, manufacturers, installers, specifiers and architects with easy access to validated, independent, supportive fire rated and acoustic door evidence...



...just scan for free access

STREBORD 44

Seal Manufacturer: Astroflame

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2668mm	926mm	1213mm	2040mm	2 No 10x4	2 No 10x4	-	A02066
LSASD	2668mm	926mm	1213mm	2040mm	1 No 15x4	1 No 15x4	-	A02066
LSASD	2668mm	926mm	1213mm	2040mm	1 No 20x4	1 No 20x4	-	A02066
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	2618mm	926mm	1188mm	2040mm	2 No 10x4	2 No 10x4	-	A02066
ULSASD	2618mm	926mm	1188mm	2040mm	1 No 15x4	1 No 15x4	-	A02066
ULSASD	2618mm	926mm	1188mm	2040mm	1 No 20x4	1 No 20x4	-	A02066
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	2498mm	926mm	1136mm	2040mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
LSADD	2498mm	926mm	1136mm	2040mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
LSADD	2498mm	926mm	1136mm	2040mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	2448mm	926mm	1111mm	2040mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
ULSADD+OP	-	-	-	-	-	-	-	-
DASD	2618mm	926mm	1188mm	2040mm	2 No 10x4	2 No 10x4	-	A02066
DASD	2618mm	926mm	1188mm	2040mm	1 No 15x4	1 No 15x4	-	A02066
DASD	2618mm	926mm	1188mm	2040mm	1 No 20x4	1 No 20x4	-	A02066
DASD+OP	-	-	-	-	-	-	-	-
ULSADD	2448mm	926mm	1111mm	2040mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
ULSADD+OP	-	-	-	-	-	-	-	-

30 Minutes Fire Performance – IFC

-

30 Minutes Fire Performance – Certifire

-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Intumescent Seals Limited

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3176mm	931mm	1099mm	2751mm	2 No 10x4	2 No 10x4	-	A02066
LSASD	3176mm	931mm	1099mm	2751mm	1 No 15x4	1 No 15x4	-	A02066
LSASD	3207mm	1012mm	1189mm	2745mm	1 No 20x4	1 No 20x4	-	A02066
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	3126mm	931mm	1074mm	2571mm	2 No 10x4	2 No 10x4	-	A02066
ULSASD	3126mm	931mm	1074mm	2571mm	1 No 15x4	1 No 15x4	-	A02066
ULSASD	3157mm	926mm	1164mm	2040mm	1 No 20x4	1 No 20x4	-	A02066
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	2498mm	926mm	1136mm	2040mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
LSADD	2498mm	926mm	1136mm	2040mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
LSADD	2498mm	1012mm	1164mm	2745mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	2448mm	926mm	1111mm	2040mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
ULSADD+OP	-	-	-	-	-	-	-	-
DASD	2618mm	926mm	1188mm	2040mm	2 No 10x4	2 No 10x4	-	A02066
DASD	2618mm	926mm	1188mm	2040mm	1 No 15x4	1 No 15x4	-	A02066
DASD	2618mm	926mm	1188mm	2040mm	1 No 20x4	1 No 20x4	-	A02066
DASD+OP	-	-	-	-	-	-	-	-
ULSADD	2448mm	926mm	1111mm	2040mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
ULSADD	2448mm	926mm	1111mm	2040mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
ULSADD+OP	-	-	-	-	-	-	-	-

30 Minutes Fire Performance – IFC

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3225mm	921mm	1215mm	2636mm	1 No 15x4	1 No 15x4	-	IFCA/08037
LSASD+OP	2778mm	833mm	1111mm	2222mm	1 No 15x4	2 No 15x4	-	IFCA/08037
ULSASD	3162mm	903mm	1192mm	2582mm	1 No 15x4	1 No 15x4	-	IFCA/08037
ULSASD+OP	2724mm	817mm	1089mm	2724mm	1 No 15x4	2 No 15x4	-	IFCA/08037
LSADD	2926mm	975mm	1103mm	2669mm	1 No 15x4	1 No 15x4	2 No 10x4	IFCA/08037
LSADD+OP	2433mm	858mm	1016mm	2117mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037
ULSADD	2897mm	965mm	1092mm	2643mm	1 No 15x4	1 No 15x4	2 No 10x4	IFCA/08037
ULSADD+OP	2309mm	777mm	915mm	2032mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037

30 Minutes Fire Performance – Certifire

-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Kilargo

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	Max Height	Jambs	Head	M/S	
LSASD	2787mm	926mm	1155mm	2403mm	2 No 10x4	2 No 10x4	-	A02066
LSASD	2787mm	926mm	1173mm	2200mm	1 No 15x4	1 No 15x4	-	A02066
LSASD	2787mm	926mm	1173mm	2200mm	1 No 20x4	1 No 20x4	-	A02066
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	-	-	-	-	-	-	-	-
ULSASD	-	-	-	-	-	-	-	-
ULSASD	-	-	-	-	-	-	-	-
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	-	-	-	-	-	-	-	-
LSADD	-	-	-	-	-	-	-	-
LSADD	-	-	-	-	-	-	-	-
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD+OP	-	-	-	-	-	-	-	-
DASD	-	-	-	-	-	-	-	-
DASD	-	-	-	-	-	-	-	-
DASD	-	-	-	-	-	-	-	-
DASD+OP	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD+OP	-	-	-	-	-	-	-	-

30 Minutes Fire Performance – IFC

-

30 Minutes Fire Performance – Certifire

-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Lorient Polyproducts Ltd

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2925mm	1072mm	1161mm	2700mm	2 No 10x4	2 No 10x4	-	A02066
LSASD	2925mm	1072mm	1161mm	2700mm	1 No 15x4	1 No 15x4	-	A02066
LSASD	3223mm	915mm	1062mm	2800mm	1 No 20x4	1 No 20x4	-	A02066
LSASD (PVC Encapsulated)	2850mm	900mm	1225mm	2100mm	Any above	Any above	-	A02066
LSASD (Multipoint Lock)	2649mm	1048mm	1153mm	2408mm	2 No 10x4	2 No 10x4	-	A02066
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	2699mm	926mm	1053mm	2399mm	2 No 10x4	2 No 10x4	-	A02066
ULSASD	2699mm	926mm	1053mm	2399mm	1 No 15x4	1 No 15x4	-	A02066
ULSASD	3713mm	915mm	1037mm	2800mm	1 No 20x4	1 No 20x4	-	A02066
ULSASD (PVC Encapsulated)	2850mm	900mm	1225mm	2100mm	Any above	Any above	-	A02066
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	2649mm	926mm	1028mm	2399mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
LSADD	2649mm	926mm	1028mm	2399mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
LSADD	2649mm	926mm	1028mm	2399mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
LSADD (PVC Encapsulated)	2800mm	900mm	1200mm	2100mm	1@15x4 or 1@20x4	1@15x4 or 1@20x4	2 No 10x4	A02066
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	2599mm	926mm	1003mm	2399mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
ULSADD	2599mm	926mm	1003mm	2399mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
ULSADD	2599mm	926mm	1003mm	2399mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
ULSADD (PVC Encapsulated)	2800mm	900mm	1200mm	2100mm	1@15x4 or 1@20x4	1@15x4 or 1@20x4	2 No 10x4	A02066
ULSADD+OP	-	-	-	-	-	-	-	-
DASD	2699mm	926mm	1053mm	2399mm	2 No 10x4	2 No 10x4	-	A02066
DASD	2699mm	926mm	1053mm	2399mm	1 No 15x4	1 No 15x4	-	A02066
DASD	3713mm	915mm	1037mm	2800mm	1 No 20x4	1 No 20x4	-	A02066
DASD (PVC Encapsulated)	2850mm	900mm	1225mm	2100mm	Any above	Any above	-	A02066
DASD+OP	-	-	-	-	-	-	-	-
DADD	2599mm	926mm	1003mm	2399mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
DADD	2599mm	926mm	1003mm	2399mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
DADD	2599mm	926mm	1003mm	2399mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
DADD (PVC Encapsulated)	2800mm	900mm	1200mm	2100mm	1@15x4 or 1@20x4	1@15x4 or 1@20x4	2 No 10x4	A02066
DADD+OP	-	-	-	-	-	-	-	-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Lorient Polyproducts Ltd (Continued)

30 Minutes Fire Performance – IFC

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2641mm	794mm	1057mm	2114mm	1 No 10x4	1 No 10x4	-	IFCA/08037
LSASD	3225mm	921mm	1215mm	2636mm	1@15x4 or 2@10x4	1@15x4 or 2@10x4	-	IFCA/08037
LSASD+OP	2778mm	833mm	1111mm	2222mm	1 No 15x4	2 No 15x4	-	IFCA/08037
ULSASD	2590mm	778mm	1036mm	2073mm	1 No 10x4	1 No 10x4	-	IFCA/08037
ULSASD	3162mm	903mm	1192mm	2582mm	1@15x4 or 2@10x4	1@15x4 or 2@10x4	-	IFCA/08037
ULSASD+OP	2724mm	817mm	1089mm	2079mm	1 No 15x4	2 No 15x4	-	IFCA/08037
LSADD	2383mm	843mm	998mm	2072mm	1 No 10x4	1 No 10x4	2 No 10x4	IFCA/08037
LSADD	2926mm	975mm	1103mm	2669mm	1@15x4 or 2@10x4	1@15x4 or 2@10x4	2 No 10x4	IFCA/08037
LSADD+OP	2433mm	858mm	1016mm	2117mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037
ULSADD	2359mm	835mm	988mm	2052mm	1 No 10x4	1 No 10x4	2 No 10x4	IFCA/08037
ULSADD	2897mm	965mm	1092mm	2643mm	1@15x4 or 2@10x4	1@15x4 or 2@10x4	2 No 10x4	IFCA/08037
ULSADD+OP	2409mm	850mm	1006mm	2096mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037

30 Minutes Fire Performance – Certifire

Config	Leaf Size				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2540mm	1165mm	1165mm	2540mm	1 No 10x4	1 No 10x4	-	CF 807
LSASD	3111mm	915mm	1016mm	2800mm	1 No 15x4	1 No 15x4	-	CF 807
LSASD	2803mm	1072mm	1113mm	2700mm	1 No 15x4	1 No 15x4	-	CF 807
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	2540mm	1165mm	1165mm	2540mm	1 No 10x4	1 No 10x4	-	CF 807
ULSASD	3111mm	915mm	1016mm	2800mm	1 No 15x4	1 No 15x4	-	CF 807
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	2600mm	1152mm	2600mm	1152mm	1 No 10x4	1 No 10x4	2 No 10x4	CF 807
LSADD	2635mm	999mm	1165mm	2259mm	1 No 15x4	1 No 15x4	1 No 15x4	CF 807
LSASD (Rebated m/s)	2600mm	1081mm	1150mm	2440mm	1 No 10x4	1 No 20x4	1 No 15x4	CF 807
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	2600mm	1152mm	2600mm	1152mm	1 No 10x4	1 No 10x4	2 No 10x4	CF 807
ULSADD	2635mm	999mm	1165mm	2259mm	1 No 15x4	1 No 15x4	1 No 15x4	CF 807
LSASD (Rebated m/s)	2600mm	1081mm	1150mm	2440mm	1 No 10x4	1 No 20x4	1 No 15x4	CF 807
ULSADD+OP	-	-	-	-	-	-	-	-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Norseal

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3740mm	926mm	1275mm	2740mm	1 No 9x1	1 No 9x1	-	A02066
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	3699mm	926mm	1250mm	2740mm	1 No 9x1	1 No 9x1	-	A02066
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	-	-	-	-	-	-	-	-
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD+OP	-	-	-	-	-	-	-	-
DASD	-	-	-	-	-	-	-	-
DASD+OP	-	-	-	-	-	-	-	-
DADD	-	-	-	-	-	-	-	-
DADD+OP	-	-	-	-	-	-	-	-

30 Minutes Fire Performance – IFC

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2604mm	801mm	1096mm	2055mm	1 No 9x1	1 No 9x1	-	IFCA/08037
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	2626mm	789mm	1051mm	2102mm	1 No 9x1	1 No 9x1	-	IFCA/08037
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	-	-	-	-	-	-	-	-
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	-	-	-	-	-	-	-	-
ULSADD+OP	-	-	-	-	-	-	-	-

30 Minutes Fire Performance – Certifire

-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Pyroplex Ltd

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2890mm	932mm	1271mm	2135mm	1 No 10x4	1 No 10x4	-	A02066
LSASD	3159mm	915mm	1204mm	2440mm	2 No 10x4	2 No 10x4	-	A02066
LSASD	3159mm	915mm	1204mm	2440mm	1 No 15x4	1 No 15x4	-	A02066
LSASD	3159mm	915mm	1204mm	2440mm	1 No 20x4	1 No 20x4	-	A02066
LSASD (Hardwood/MDF Frame only)	3365mm	915mm	1280mm	2442mm	2@10, 1@15 or 1@20x4	2@10, 1@15 or 1@20x4	-	A02066
LSASD (Over-rebated)	2466mm	955mm	1096mm	2155mm	2 No 10x4	2 No 10x4	-	A02066
LSASD (Multipoint Lock)	3247mm	1046mm	1412mm	2405mm	2 No 10x4	2 No 10x4	-	A02066
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	2840mm	932mm	1246mm	2135mm	1 No 10x4	1 No 10x4	-	A02066
ULSASD	3109mm	915mm	1179mm	2440mm	2 No 10x4	2 No 10x4	-	A02066
ULSASD	3109mm	915mm	1179mm	2440mm	1 No 15x4	1 No 15x4	-	A02066
ULSASD	3109mm	915mm	1179mm	2440mm	1 No 20x4	1 No 20x4	-	A02066
ULSASD (Hardwood/MDF Frame only)	3315mm	915mm	1255mm	2442mm	2@10, 1@15 or 1@20x4	2@10, 1@15 or 1@20x4	-	A02066
ULSASD (Over-rebated)	2416mm	955mm	1071mm	2155mm	2 No 10x4	2 No 10x4	-	A02066
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	2790mm	932mm	1221mm	2135mm	1 No 10x4	1 No 10x4	2 No 10x4	A02066
LSADD	3059mm	915mm	1154mm	2440mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
LSADD	3059mm	915mm	1154mm	2440mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
LSADD	3059mm	915mm	1154mm	2440mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
LSADD (Hardwood/MDF Frame only)	3265mm	915mm	1230mm	2442mm	2@10, 1@15 or 1@20x4	2@10, 1@15 or 1@20x4	2 No 10x4	A02066
LSADD (Over-rebated)	-	-	-	-	-	-	-	-
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	2740mm	932mm	1196mm	2135mm	1 No 10x4	1 No 10x4	2 No 10x4	A02066
ULSADD	3009mm	915mm	1129mm	2440mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
ULSADD	3009mm	915mm	1129mm	2440mm	1 No 15x4	1 No 15x4	2 No 10x4	A02066
ULSADD	3009mm	915mm	1129mm	2440mm	1 No 20x4	1 No 20x4	2 No 10x4	A02066
ULSADD (Hardwood/MDF Frame only)	3215mm	915mm	1205mm	2442mm	2@10, 1@15 or 1@20x4	2@10, 1@15 or 1@20x4	2 No 10x4	A02066
ULSADD (Over-rebated)	-	-	-	-	-	-	-	-
ULSADD+OP	-	-	-	-	-	-	-	-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Pyroplex Ltd (Continued)

30 Minutes Fire Performance – Q Mark (Continued)

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
DASD	2840mm	932mm	1246mm	2135mm	1 No 10x4	1 No 10x4	-	A02066
DASD	3109mm	915mm	1179mm	2440mm	2 No 10x4	2 No 10x4	-	A02066
DASD	3109mm	915mm	1179mm	2440mm	1 No 15x4	1 No 15x4	-	A02066
DASD	3109mm	915mm	1179mm	2440mm	1 No 20x4	1 No 20x4	-	A02066
DASD (Hardwood/MDF Frame only)	3315mm	915mm	1255mm	2442mm	2@10, 1@15 or 1@20x4	2@10, 1@15 or 1@20x4	-	A02066
DASD (Over-rebated)	-	-	-	-	-	-	-	-
DASD+OP	-	-	-	-	-	-	-	-
DADD	2740mm	932mm	1196mm	2135mm	1 No 10x4	1 No 10x4	-	A02066
DADD	3009mm	915mm	1129mm	2440mm	2 No 10x4	2 No 10x4	-	A02066
DADD	3009mm	915mm	1129mm	2440mm	1 No 15x4	1 No 15x4	-	A02066
DADD	3009mm	915mm	1129mm	2440mm	1 No 20x4	1 No 20x4	-	A02066
DADD (Hardwood/MDF Frame only)	3215mm	915mm	1205mm	2442mm	2@10, 1@15 or 1@20x4	2@10, 1@15 or 1@20x4	-	A02066
DADD (Over-rebated)	-	-	-	-	-	-	-	-
DADD+OP	-	-	-	-	-	-	-	-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Pyroplex Ltd (Continued)

30 Minutes Fire Performance – IFC

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3225mm	921mm	1215mm	2636mm	1 No 15x4	1 No 15x4	-	IFCA/08037
LSASD+OP	2778mm	833mm	1111mm	2222mm	1 No 15x4	2 No 15x4	-	IFCA/08037
ULSASD	3162mm	903mm	1102mm	2582mm	1 No 15x4	1 No 15x4	-	IFCA/08037
ULSASD+OP	2724mm	817mm	1089mm	2179mm	1 No 15x4	2 No 15x4	-	IFCA/08037
LSADD	2912mm	970mm	1099mm	2655mm	1 No 15x4	1 No 15x4	2 No 10x4	IFCA/08037
LSADD+OP	2332mm	785mm	924mm	2052mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037
ULSADD	2884mm	961mm	1088mm	2629mm	1 No 15x4	1 No 15x4	2 No 10x4	IFCA/08037
ULSADD+OP	2309mm	777mm	915mm	2032mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037

30 Minutes Fire Performance – Certifire

Config	Leaf Size				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 10x4	-	CF 807
LSASD+OP	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 15x4	-	CF 807
ULSASD	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 10x4	-	CF 807
ULSASD+OP	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 15x4	-	CF 807
LSADD	2942mm	1165mm	1165mm	2942mm	1 No 10x4	1 No 10x4	2 No 10x4	CF 807
LSADD+OP	2635mm	999mm	1165mm	2259mm	1 No 10x4	1 No 15x4	2 No 10x4	CF 807
ULSADD	2942mm	1165mm	1165mm	2942mm	1 No 10x4	1 No 10x4	2 No 10x4	CF 807
ULSADD+OP	2635mm	999mm	1165mm	2259mm	1 No 10x4	1 No 15x4	2 No 10x4	CF 807

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Sealmaster

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2393mm	926mm	1094mm	2039mm	1 No 9.5x7.5	1 No 9.5x7.5	-	A02066
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	2343mm	926mm	1069mm	2039mm	1 No 9.5x7.5	1 No 9.5x7.5	-	A02066
ULSASD+OP	-	-	-	-	-	-	-	-
LSADD	2293mm	926mm	1044mm	2039mm	1 No 9.5x7.5	1 No 9.5x7.5	1 No 9.5x7.5	A02066
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	2243mm	926mm	1019mm	2039mm	1 No 9.5x7.5	1 No 9.5x7.5	1 No 9.5x7.5	A02066
ULSADD+OP	-	-	-	-	-	-	-	-
DASD	2343mm	926mm	1069mm	2039mm	1 No 9.5x7.5	1 No 9.5x7.5	-	A02066
DASD+OP	-	-	-	-	-	-	-	-
DADD	2243mm	926mm	1019mm	2039mm	1 No 9.5x7.5	1 No 9.5x7.5	1 No 9.5x7.5	A02066
DADD+OP	-	-	-	-	-	-	-	-

30 Minutes Fire Performance – IFC

-

30 Minutes Fire Performance – Certifire

-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Sealed Tight Solutions Ltd

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3283mm	1050mm	1416mm	2440mm	2 No 10x4	2 No 10x4	-	A02066
LSASD	3283mm	1050mm	1416mm	2440mm	1 No 15x4	1 No 15x4	-	A02066
LSASD	3317mm	1000mm	1175mm	2900mm	1 No 15x4	1 No 15x4	-	BMT/CNA/F15056
LSASD	3283mm	1050mm	1416mm	2440mm	1 No 20x4	1 No 20x4	-	A02066
LSASD (PVC Encapsulated)	2581mm	1005mm	1306mm	2205mm	Any Above	Any Above	-	A02066
LSASD (Multipoint Lock)	3235mm	1050mm	1550mm	2235mm	2 No 10x4	2 No 10x4	-	A02066
LSASD (Multipoint Lock)	2746mm	1175mm	1175mm	2746mm	2 No 10x4	2 No 10x4	-	BMT/CNA/F15056
LSASD+OP	-	-	-	-	-	-	-	-
ULSASD	3145mm	1000mm	1100mm	2900mm	2 No 10x4	2 No 10x4	-	A02066
ULSASD	3267mm	1000mm	1150mm	2900mm	1 No 15x4	1 No 15x4	-	BMT/CNA/F15056
ULSASD	3145mm	1000mm	1100mm	2900mm	1 No 20x4	1 No 20x4	-	A02066
ULSASD (PVC Encapsulated)	2801mm	1005mm	1281mm	2205mm	Any Above	Any Above	-	A02066
ULSASD+OP	-	-	-	-	-	-	-	-
DASD	3145mm	1000mm	1100mm	2900mm	2 No 10x4	2 No 10x4	-	A02066
DASD	3267mm	1000mm	1150mm	2900mm	1 No 15x4	1 No 15x4	-	BMT/CNA/F15056
DASD	3145mm	1000mm	1100mm	2900mm	1 No 20x4	1 No 20x4	-	A02066
DASD (PVC Encapsulated)	2801mm	1005mm	1281mm	2205mm	Any Above	Any Above	-	A02066
DASD+OP	-	-	-	-	-	-	-	-
LSADD	3233mm	1050mm	1391mm	2440mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
LSADD	3233mm	1050mm	1391mm	2440mm	1 No 15x4	1 No 15x4	1 No 15x4	A02066
LSADD	3167mm	1000mm	1100mm	2900mm	1 No 15x4	1 No 15x4	2 No 10x4	BMT/CNA/F15056
LSADD	3233mm	1050mm	1391mm	2440mm	1 No 20x4	1 No 20x4	1 No 20x4	A02066
LSADD (PVC Encapsulated)	2751mm	1005mm	1256mm	2205mm	1@15x4 or 1@20x4	1@15x4 or 1@20x4	1@15x4 or 1@20x4	A02066
LSADD+OP	-	-	-	-	-	-	-	-
ULSADD	3045mm	1050mm	1050mm	2440mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
ULSADD	3045mm	1050mm	1050mm	2440mm	1 No 15x4	1 No 15x4	1 No 15x4	A02066
ULSADD	3117mm	1000mm	1075mm	2900mm	1 No 15x4	1 No 15x4	2 No 10x4	BMT/CNA/F15056
ULSADD	3045mm	1050mm	1050mm	2440mm	1 No 20x4	1 No 20x4	1 No 20x4	A02066
ULSADD (PVC Encapsulated)	2701mm	1005mm	1231mm	2205mm	1@15x4 or 1@20x4	1@15x4 or 1@20x4	1@15x4 or 1@20x4	A02066
ULSADD+OP	-	-	-	-	-	-	-	-
DADD	3045mm	1050mm	1050mm	2440mm	2 No 10x4	2 No 10x4	2 No 10x4	A02066
DADD	3045mm	1050mm	1050mm	2440mm	1 No 15x4	1 No 15x4	1 No 15x4	A02066
DADD	3117mm	1000mm	1075mm	2900mm	1 No 15x4	1 No 15x4	2 No 10x4	BMT/CNA/F15056
DADD	3045mm	1050mm	1050mm	2440mm	1 No 20x4	1 No 20x4	1 No 20x4	A02066
DADD (PVC Encapsulated)	2701mm	1005mm	1231mm	2205mm	1@15x4 or 1@20x4	1@15x4 or 1@20x4	1@15x4 or 1@20x4	A02066
DADD+OP	-	-	-	-	-	-	-	-

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Seal Manufacturer: Sealed Tight Solutions Ltd (Continued)

30 Minutes Fire Performance – IFC

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3203mm	915mm	1252mm	2528mm	1 No 15x4	1 No 15x4	-	IFCA/08037
LSASD+OP	2651mm	764mm	1044mm	2089mm	1 No 15x4	2 No 15x4	-	IFCA/08037
ULSASD	3148mm	899mm	1187mm	2572mm	1 No 15x4	1 No 15x4	-	IFCA/08037
ULSASD+OP	2599mm	749mm	1024mm	2049mm	1 No 15x4	2 No 15x4	-	IFCA/08037
LSADD	2912mm	970mm	1099mm	2655mm	1 No 15x4	1 No 15x4	2 No 10x4	IFCA/08037
LSADD+OP	2332mm	785mm	924mm	2052mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037
ULSADD	2884mm	961mm	1088mm	2629mm	1 No 15x4	1 No 15x4	2 No 10x4	IFCA/08037
ULSADD+OP	2309mm	777mm	915mm	2032mm	1 No 15x4	2 No 15x4	2 No 10x4	IFCA/08037

30 Minutes Fire Performance – Certifire

Config	Leaf Size				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 10x4	-	CF 807
LSASD+OP	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 15x4	-	CF 807
ULSASD	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 10x4	-	CF 807
ULSASD+OP	3111mm	915mm	1016mm	2800mm	1 No 10x4	1 No 15x4	-	CF 807
LSADD	2942mm	1165mm	1165mm	2942mm	1 No 10x4	1 No 10x4	2 No 10x4	CF 807
LSADD+OP	2635mm	999mm	1165mm	2259mm	1 No 10x4	1 No 15x4	2 No 10x4	CF 807
ULSADD	2942mm	1165mm	1165mm	2942mm	1 No 10x4	1 No 10x4	2 No 10x4	CF 807
ULSADD+OP	2635mm	999mm	1165mm	2259mm	1 No 10x4	1 No 15x4	2 No 10x4	CF 807

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 54

60 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3155mm	927mm	1085mm	2757mm	2 No 15x4	2 No 15x4	-	A02067
LSASD	2528mm	1234mm	1271mm	2454mm	2 No 15x4	2 No 15x4	-	A02067
LSASD (Multipoint Lock)	2542mm	1048mm	1109mm	2402mm	2 No 15x4	2 No 15x4	-	WF427764
LSASD+OP	2405mm	915mm	1055mm	2120mm	1 No 15x4	1@25x4 & 1@15x4	-	A02067
ULSASD	3105mm	927mm	1060mm	2757mm	2 No 15x4	2 No 15x4	-	A02067
ULSASD	2478mm	1234mm	1246mm	2454mm	2 No 15x4	2 No 15x4	-	A02067
ULSASD+OP	2355mm	915mm	1055mm	2120mm	1 No 15x4	1@25x4 & 1@15x4	-	A02067
LSADD	3055mm	927mm	1035mm	2757mm	2 No 15x4	2@15x4 & 1@15x4	2 No 15x4	A02067
LSADD	2310mm	925mm	1050mm	2040mm	2 No 15x4	2 No 15x4	2 No 15x4	A02067
LSADD+OP	2205mm	915mm	955mm	2120mm	2 No 15x4	1@25x4 & 1@15x4	2 No 15x4	A02067
ULSADD	3005mm	927mm	1010mm	2757mm	2 No 15x4	2 No 15x4	2 No 15x4	A02067
ULSADD	2260mm	925mm	1025mm	2040mm	2 No 15x4	2 No 15x4	2 No 15x4	A02067
ULSADD+OP	2155mm	915mm	930mm	2120mm	2 No 15x4	1@25x4 & 1@15x4	2 No 15x4	A02067
DASD	3105mm	927mm	1060mm	2757mm	2 No 15x4	2 No 15x4	-	A02067
DASD	2478mm	1234mm	1246mm	2454mm	2 No 15x4	2 No 15x4	-	A02067
DASD+OP	2355mm	915mm	1055mm	2120mm	1 No 15x4	1@25x4 & 1@15x4	-	A02067
DADD	3005mm	927mm	1010mm	2757mm	2 No 15x4	2 No 15x4	2 No 15x4	A02067
DADD	2260mm	925mm	1025mm	2040mm	2 No 15x4	2 No 15x4	2 No 15x4	A02067
DADD+OP	2155mm	915mm	930mm	2120mm	2 No 15x4	1@25x4 & 1@15x4	2 No 15x4	A02067

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 54

(Continued)

60 Minutes Fire Performance – IFC

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3180mm	908mm	1117mm	2763mm	2 No 15x4	2@15x4 & 1@15x4	-	IFCA/08038
LSASD+OP	3133mm	895mm	1107mm	2709mm	2 No 15x4	1@38x4 & 1@15x4	-	IFCA/08038
ULSASD	3118mm	891mm	1102mm	2696mm	2 No 15x4	2@15x4 & 1@15x4	-	IFCA/08038
ULSASD+OP	3072mm	877mm	1085mm	2656mm	2 No 15x4	1@38x4 & 1@15x4	-	IFCA/08038
LSADD	2885mm	961mm	1018mm	2773mm	2 No 15x4	2@15x4 & 1@15x4	2 No 15x4	IFCA/08038
LSADD+OP	2802mm	934mm	994mm	2681mm	2 No 15x4	1@38x4 & 1@15x4	2 No 15x4	IFCA/08038
ULSADD	2857mm	952mm	1013mm	2733mm	2 No 15x4	2@15x4 & 1@15x4	2 No 15x4	IFCA/08038
ULSADD+OP	2775mm	825mm	984mm	2655mm	2 No 15x4	1@38x4 & 1@15x4	2 No 15x4	IFCA/08038

60 Minutes Fire Performance – Certifire

Config	Leaf Size				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	3242mm	1035mm	1177mm	2850mm	2 No 15x4	2 No 15x4	-	CF 808
LSASD+OP	2249mm	935mm	985mm	2135mm	2 No 15x4	1@15x4 & 1@25x4	-	CF 808
ULSASD	2517mm	1234mm	1265mm	2454mm	2 No 15x4	2 No 15x4	-	CF 808
ULSASD+OP	2249mm	935mm	985mm	2135mm	2 No 15x4	1@15x4 & 1@25x4	-	CF 808
LSADD	3257mm	936mm	1106mm	2757mm	2 No 15x4	2 No 15x4	2 No 15x4	CF 808
LSADD+OP	2249mm	935mm	985mm	2135mm	2 No 15x4	1@15x4 & 1@25x4	2 No 15x4	CF 808
ULSADD	2249mm	935mm	985mm	2135mm	2 No 15x4	2 No 15x4	2 No 15x4	CF 808
ULSADD+OP	2249mm	935mm	985mm	2135mm	2 No 15x4	1@15x4 & 1@25x4	2 No 15x4	CF 808

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44 PANELLED

30 Minutes Fire Performance – Q Mark

Config	Leaf Sizes				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2979mm	932mm	1310mm	2135mm	1 No 20x4	1 No 20x4	-	Chilt/A09104
ULSASD	2929mm	932mm	1285mm	2135mm	1 No 20x4	1 No 20x4	-	Chilt/A09104
LSADD	2879mm	932mm	1260mm	2135mm	1 No 20x4	1 No 20x4	1 No 20x4	Chilt/A09104
ULSADD	2829mm	932mm	1235mm	2135mm	1 No 20x4	1 No 20x4	1 No 20x4	Chilt/A09104
DASD	2929mm	932mm	1285mm	2135mm	1 No 20x4	1 No 20x4	-	Chilt/A09104
DADD	2829mm	932mm	1235mm	2135mm	1 No 20x4	1 No 20x4	1 No 20x4	Chilt/A09104

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 54 PANELLED

30 Minutes Fire Performance – Q Mark

Config	Leaf Size				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2979mm	932mm	1310mm	2135mm	1 No 20x4	1 No 20x4	-	Chilt/A09104
ULSASD	2929mm	932mm	1285mm	2135mm	1 No 20x4	1 No 20x4	-	Chilt/A09104
LSADD	2879mm	932mm	1260mm	2135mm	1 No 20x4	1 No 20x4	1 No 20x4	Chilt/A09104
ULSADD	2829mm	932mm	1235mm	2135mm	1 No 20x4	1 No 20x4	1 No 20x4	Chilt/A09104
DASD	2929mm	932mm	1285mm	2135mm	1 No 20x4	1 No 20x4	-	Chilt/A09104
DADD	2829mm	932mm	1235mm	2135mm	1 No 20x4	1 No 20x4	1 No 20x4	Chilt/A09104

60 Minutes Fire Performance – Q Mark

Config	Leaf Size				Seal Arrangement			Doc Link
	Max Height	At Width	Max Width	At Height	Jambs	Head	M/S	
LSASD	2040mm	928mm	928mm	2040mm	2 No 15x4	2 No 15x4	-	Chilt/A10152

The above intumescent seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 44

Acoustic Performance

Config	Acoustic Seal(s)				Glass Type	dB(Rw) Rating
	Jambs	Head	M/S	Threshold		
Single Flush	FAS35	FAS35	-	FAS45	-	33dB
Single Flush	LAS1212	LAS1212	-	LAS8001 si	-	32dB
Single Flush	NOR710	NOR710	-	NOR810 & NOR650	-	33dB
Single Flush	Harmony Twin Flipper	Harmony Twin Flipper	-	Harmony HID	-	33dB
Single Flush	STS 1009	STS 1009	-	STS 422	-	33dB
Single Glazed	FAS35	FAS35	-	FAS45	7mm Pyroguard	35dB
Single Glazed	LAS1212K	LAS1212K	-	LAS8001 si	15mm Pyrostop	35dB
Single Glazed	ACS-1 & 15x4 PSA	ACS-1 & 15x4 PSA	-	1703 ACU	7mm Pyrodur	35dB
Single Glazed	NOR710	NOR710	-	NOR810 & NOR650	15mm Pyrostop	35dB
Pair Flush	NOR710	NOR710	NOR720	NOR810	-	33dB
Pair Flush	LAS1011	LAS1011	LAS1011 (x2)	LAS8001 si	-	32dB
Pair Flush	ST1009	ST1009	STS 104SBS single-blade seal	ST422	-	31dB
Pair Glazed	FAS39	FAS39	DGS Astragal Seal & DGS Intumescent / Twin Seal	FAS45	15mm Pyrostop	35dB
Pair Glazed	LAS1212 & LAS1011	LAS1212 & LAS1011	LP1004DS (x2)	LAS8001 si	15mm Pyroguard	35dB
Pair Glazed	ACS-1 & PSSSA twin 15x4	ACS-1 & PSSSA twin 15x4	PSSA twin 15x4 & Astragal 7061	420S	15mm Pyrostop	35dB
Pair Glazed	NOR710	NOR710	NOR755 & NOR720	NOR850 & NOR615	15mm Pyrostop	35dB

The above acoustic seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

STREBORD 54

Acoustic Performance

Config	Acoustic Seal(s)				Glass Type	dB(Rw) Rating
	Jamb	Head	M/S	Threshold		
Single Flush	STS 1009	STS 1009	-	STS 422	-	35dB
Single Flush	LP1504DS & LAS1212	LP1504DS & LAS1212	-	LAS8001 si	-	35dB
Single Flush	NOR710 & NOR720	NOR710 & NOR720	-	NOR810	-	35dB
Single Glazed	FAS35	FAS35	-	FAS45	11.4mm Pyroguard	35dB
Single Glazed	ACS-1 & 15 x 4 PSA	ACS-1 & 15 x 4 PSA	-	1703-ACU	15mm Pyrostop	35dB
Single Glazed	NOR710	NOR710	-	NOR810	7mm Pyrobelite	35dB
Single Glazed	LP1504DS & LAS1212	LP1504DS & LAS1212	-	LAS8001 si	11mm Pyroguard	36dB
Single Glazed	ST1009	ST1009	-	ST422	15mm Glass	35dB
Pair Flush	FAS35	FAS35	FAS35	FAS45	-	33dB
Pair Flush	LP1504DS & LAS1212	LP1504DS & LAS1212	LP1504 & LP1504DS	LAS8001 si	-	32dB
Pair Flush	NOR710	NOR710	NOR720	NOR810	-	33dB
Pair Flush	STS 1009	STS 1009	STS 154SBS	STS 422	-	35dB
Pair Glazed	FAS35	FAS35	15x4 Dual Seal	FAS45	12mm Pyrobelite	35dB
Pair Glazed	NOR710	NOR710	NOR720	NOR720 & NOR615	10mm Pyrostop	35dB
Pair Glazed	LP1504DS (x2)	LP1504DS (x2)	LP1504DS (x2)	LAS8001 si	15mm Pyroguard	36dB
Pair Glazed	ST1009	ST1009	STS 154SBS single-blade sea	ST422	15mm Glass	35dB

The above acoustic seal configurations are a summary of available performances only. Individual seal manufacturers may have carried out additional independent testing which they could make available to doorset providers.

Contact us for more information



Gateshead Depot
 Haydock Depot
 High Wycombe Depot
 Leeds Depot
 Nottingham Depot
 Tilbury Depot
 West Bromwich Depot

T 0191 338 8208
 T 01744 416 600
 T 01494 291 777
 T 0113 887 2222
 T 0115 919 2000
 T 01375 487 300
 T 0121 525 8844

E gateshead@falconpp.co.uk
 E haydock@falconpp.co.uk
 E highwycombe@falconpp.co.uk
 E leeds@falconpp.co.uk
 E nottingham@falconpp.co.uk
 E tilbury@falconpp.co.uk
 E westbrom@falconpp.co.uk

Falcon Panel Products Ltd
 Clock House
 Station Approach
 Shepperton, Middlesex
 TW17 8AN
 E sales@falconpp.co.uk
www.falconpp.co.uk

